

10/07/2011

D-Shift

Johnson

1924 - Completed Shift Brief with D-Shift.

2145 - Moved Red Arrow on use of AP-02D pump to ATB-11-014, clearing Red Arrow, pg. 246 @ 0001.

0000 10/08/2011

D-Shift

Johnson

0453 - Relieved as CSM by R. Malhan.

0453 - ASSUMED DUTIES of BO CSM. R. Malhan

0718 - CONDUCTED PRE-SHIFT BRIEF WITH A-SHIFT CSM.

1100 - IHT COMPLETED FLAMMABLE GDS CHECKS for AN farm, AP farm &amp; SY farm. ALL TANKS ARE READING 0% LFL.

o NEXT AP farm SR 3.1.1 DUE NLT 10/23/11 @ 0958 hrs

o NEXT AN farm SR 3.1.1 DUE NLT 10/28/11 @ 0730 hrs

o NEXT SY farm SR 3.1.1 DUE NLT 11/11/12 @ 0852 hrs

o NEXT AN farm SR 3.1.1 DUE NLT 10/23/11 @ 0958 hrs

1640 - RECEIVED AS BO CSM @ 4 BLW JOURNAL. R. Malhan

1640 - Reviewed logbook, assumed duties of CSM.

1915 - Completed Shift Brief with D-Shift.

0000 10/09/2011

D-Shift

Johnson

SUNDAY -

0446 - Relieved as CSM by R. Malhan.

0446 - ASSUMED DUTIES of BO CSM. R. Malhan

0719 - CONDUCTED PRE-SHIFT BRIEF WITH A-SHIFT CSM.

LOW TEMP FOR THIS MORNING WAS 46 OF.

0830 - IHT COMPLETED FLAM GDS CHECKS for AY &amp; AZ farm.

ALL TANKS ARE READING 0% LFL.

o NEXT AY farm SR 3.1.1 DUE NLT 10/14/11 @ 0758 hrs

o NEXT AZ farm SR 3.1.1 DUE NLT 10/14/11 @ 0803 hrs

0850 - NETWORK OPERATION CENTRAL REPORTS POSSIBLE LOSS OF POWER TO THE NETWORK EQUIPMENT @ MO-TLY AREA NABU TRAIL.

0917 - CONTACTED ELEC UTILITIES TO VERIFY ELEC OUTAGE STATUS FOR 0850-HR LOC ENTRY.

1215 - TMA'S RELEASE AP-10L ANNULUS ENRAF 8090 IS SHOWING A STEADY INCREASE SINCE MIDNIGHT &amp; IS IN ALARM. OTHER TWO ENRAFS ARE HOLDING STEADY &amp; NOT IN ALARM. UNABLE TO FIND APC. VERIFIED PRIMARY TANK LEVEL HAS NOT CHANGED. DISPATCHED ERI TO VERIFY ENRAF FIELD READING.

LOAN  
10/10/11

1236 - ERI VERIFIED AP-10L ANNULUS ENRAF 8090 IS THE FIRST TO RECOVER SAME AS TMA @ 0.26".